

KNOXVILLE/KNOX COUNTY METROPOLITAN PLANNING COMMISSION CITY OF KNOXVILLE CLOSURE OF PUBLIC RIGHT-OF-WAY

► FILE #: 8-B-08-SC AGENDA ITEM #: 9

AGENDA DATE: 8/14/2008

► APPLICANT: KCDC

TAX ID NUMBER: 81 P R 001

JURISDICTION: Council District 5

SECTOR PLAN: Central City

GROWTH POLICY PLAN: Urban Growth Area (Inside City Limits)

ZONING: R-2 (General Residential) / IH-1 (Infill Housing Overlay)

WATERSHED: Third Creek

► RIGHT-OF-WAY TO BE

CLOSED:

Badgett Dr.

► LOCATION: Between Goins Dr. southeast and Unnamed alley

IS STREET:

(1) IN USE?: No(2) IMPROVED (paved)?: No

► APPLICANT'S REASON FOR CLOSURE:

This section of Badgett has been abandoned as part of the renovation

of the adjoining residential property.

DEPARTMENT-UTILITY

REPORTS:

No objections received as of 7/20/08: subject to any required easements

STAFF RECOMMENDATION:

► APPROVE the closure of this street section, subject to any required easements.


This street section has been abandoned as part of the renovation of the adjoining residential neighborhood and is no longer needed for vehicular access in the area.

COMMENTS:

This street section has been incorporated into the adjoining residential yard space for the enjoyment of the residents

If approved, this item will be forwarded to Knoxville City Council for action on 9/9/2008 and 9/23/2008. If denied, MPC's action is final, unless the action to deny is appealed to Knoxville City Council. The date of the appeal hearing will depend on when the appeal application is filed. Appellants have 15 days to appeal an MPC decision in the City.

AGENDA ITEM #: 9 FILE #: 8-B-08-SC 8/5/2008 08:19 AM KEN PRUITT PAGE #: 9-1





July 25, 2008

Mr. Ken Pruitt Knoxville-Knox County Metropolitan Planning Commission Suite 403, City-County Building Knoxville, Tennessee 37902



Dear Mr. Pruitt:

Re: Right-of-Way Closure Request 8-B-08-SC

We have reviewed our records and find that we have existing utility facilities located within the subject right-of-way. The approximate location of these facilities is indicated on the attached prints. However, KUB does not release and hereby retains all easements and rights for existing utility facilities, whether or not shown on these prints.

Should this right-of-way be closed, KUB will require the following permanent easement for its utility.

Water -7.5 feet on each side of the centerline of the water line, 15 feet total width Gas -12.5 feet on each side of the centerline of the gas line, 25 feet total width

So long as these conditions are met, KUB has no objection to the closure of this right-of-way. If you have any questions regarding this matter, please call me at (865) 558-2752.

Sincerely.

Cheryl E. Myers
Engineering

cem/ggt

Enclosure

ROW Closure - 8-B-08-SC - Badgett Dr @Goins - Water - Maintain 15' Easement

ROW Closure - 8-B-08-SC - Badgett Dr @ Goins - Gas - Maintain 25' Easement