




Knoxville Utilities Board

July 25, 2008

Mr. Ken Pruitt
Knoxville-Knox County
Metropolitan Planning Commission
Suite 403, City-County Building
Knoxville, Tennessee 37902



Dear Mr. Pruitt:

Re: Right-of-Way Closure Request 8-B-08-SC

We have reviewed our records and find that we have existing utility facilities located within the subject right-of-way. The approximate location of these facilities is indicated on the attached prints. However, KUB does not release and hereby retains all easements and rights for existing utility facilities, whether or not shown on these prints.

Should this right-of-way be closed, KUB will require the following permanent easement for its utility facility.

Water – 7.5 feet on each side of the centerline of the water line, 15 feet total width
Gas – 12.5 feet on each side of the centerline of the gas line, 25 feet total width

So long as these conditions are met, KUB has no objection to the closure of this right-of-way. If you have any questions regarding this matter, please call me at (865) 558-2752.


Sincerely,

Cheryl E. Myers
Engineering

cem/ggt

Enclosure

ROW Closure - 8-B-08-SC - Badgett Dr @Goins - Water - Maintain 15' Easement



ROW Closure - 8-B-08-SC - Badgett Dr @ Goins Dr - Gas - Maintain 25' Easement

