



September 15, 2008

Mr. Ken Pruitt Knoxville-Knox County Metropolitan Planning Commission Suite 403, City-County Building Knoxville, Tennessee 37902

Dear Mr. Pruitt:

Re: Right-of-Way Closure Request 10-A-08-AC

We have reviewed our records and find that we have existing utility facilities located within the subject right-of-way. The approximate location of these facilities is indicated on the attached prints. However, KUB does not release and hereby retains all easements and rights for existing utility facilities, whether or not shown on these prints.

Should this right-of-way be closed, KUB will require the following permanent easement for its utility.

Electric – 10 feet on each side of the centerline or the electric line, 20 feet total width

So long as these conditions are met, KUB has no objection to the closure of this right-of-way. If you have any questions regarding this matter, please call me at (865) 558-2752.

Sincerely,

Cheryl E. Myers

Cheryl E. Myers

Engineering

cem/ggt

Enclosure

Right-of-Way Closure 10-A-08-AC - Electric - Maintain 20' Easement