## 2-A-11-SC\_cor\_ KUB



JAN 1 2 350

January 11, 2011



Mr. Ken Pruitt Knoxville-Knox County Metropolitan Planning Commission Suite 403, City-County Building Knoxville, Tennessee 37902

Dear Mr. Pruitt:

## Re: Right-of-Way Closure Request 2-A-11-SC

We have reviewed our records and find that we have existing utility facilities located within the subject right-of-way. The approximate location of these facilities is indicated on the enclosed prints. However, KUB does not release and hereby retains all easements and rights for existing utility facilities, whether or not shown on these prints.

Should this right-of-way be closed, KUB will require the following permanent easement for its utility

Electric - 10 feet on each side of the centerline of the electric line, 20 feet total width Gas - 7.5 feet on each side of the centerline of the gas line, 15 feet total width Sewer - 7.5 feet on each side of the centerline of the wastewater line, 15 feet total width Water - 7.5 feet on each side of the centerline of the water line, 15 feet total width

So long as these conditions are met, KUB has no objection to the closure of this right-of-way. If you have any questions regarding this matter, please call me at (865) 558-2291.

Sincerely,

Greg L. Patterson, P.E.

Engineering

glp/ggt

Enclosure

W

(Ashe Ave to TDOT ROW) ELECTRIC 1" = 60"

GAS 1'' = 60'

(Ashe Ave to TDOT ROW)

1" = 60'

SEWER

(Ashe Ave to TDOT ROW)

(Ashe Ave to TDOT ROW) WATER 1" = 60'