


3-B-11-SC-Cor-Bellsouth

3-A-11-SC

3-B-11-SC

FAX



Date 02-22-2011

Number of pages including cover sheet 3

**TO: Mike Brusseau
MPC**

**FROM: JOHN T. STEMPA
AT&T
9733 PARKSIDE DR
KNOXVILLE, TN 37922**

Phone 865-215-2500

Phone 865-539-8582

Fax Phone 865-215-2068

Fax 865-470-8519

CC:

REMARKS: Urgent For your review Reply ASAP Please Comment

Mike

I have reviewed the Right-Of-Way closure letters for Bonnyman Dr and Testerman Dr. AT&T will require access when the time comes to remove the plant. The cable along Bonnyman Dr is all buried plant and I show there are no working numbers. The cable along Testerman Dr is aerial plant but there too, I show no working numbers.

I have attached a plat showing our cable for each area. Bonnyman Dr. will be hard to read, so if you want it larger, please call me.

Thanks

John Stempa



Knoxville Utilities Board

February 3, 2011

Mr. Mike Brusseau
Knoxville-Knox County
Metropolitan Planning Commission
Suite 403, City-County Building
Knoxville, Tennessee 37902

Dear Mr. Brusseau:

Re: Right-of-Way Closure Request 3-B-11-SC

We have reviewed our records and find that we have existing utility facilities located within the subject right-of-way. The approximate location of these facilities is indicated on the enclosed prints. However, KUB does not release and hereby retains all easements and rights for existing utility facilities, whether or not shown on these prints.

Should this right-of-way be closed, KUB will require the following permanent easement for its utility facility.

Electric – 10 feet on each side of the centerline of the electric – 20 feet total width

So long as these conditions are met, KUB has no objection to the closure of this right-of-way. If you have any questions regarding this matter, please call me at (865) 558-2291

Sincerely,

A handwritten signature in cursive script that reads 'Greg Patterson'.

Greg L. Patterson, P.E.
Engineering

glt/ggt

Enclosure

